



**NOTES:**

1. VALVE VAULT OPENING SHALL BE CENTERED OVER VALVE & CASTING TO BE SET AT FINISH GRADE AS SHOWN ON PLANS.
2. PRECAST CONCRETE VAULT SHALL HAVE AN INSIDE DIAMETER OF 60" (MINIMUM) FOR 8" DIA. WATER MAIN AND LARGER.
3. VALVES SHALL BE RESILIENT WEDGE GATE VALVES CONFORMING TO AWWA C-515 AND SHALL BE CLOW OR APPROVED EQUAL.
4. ALL NUTS AND BOLTS ON VALVE ARE TO BE STAINLESS STEEL.
5. MEG-A-LUGS SHALL BE USED.
6. RUBBER BOOT CONNECTOR ASSEMBLY SHALL MEET ASTM C923 REQUIREMENTS.
7. PROVIDE A ½" LAYER OF PREFORMED JOINT FILLER BETWEEN PEDESTAL AND VALVE.
8. THE OPERATING NUT SHALL BE LOCATED DIRECTLY BELOW THE VALVE VAULT LID. ALL VALVES SHALL BE "KEYABLE" AS DETERMINED BY THE CITY OF BATAVIA WATER DEPARTMENT.

NOT TO SCALE



**CITY OF BATAVIA  
PUBLIC WORKS DEPARTMENT**

SHEET: 1 OF 1  
DATE: 7/10/20

**WATER VALVE VAULT**

**STANDARD NO. 6.01**