



NOTE:

1. HYDRANT, VALVE AND TEE SHALL BE SECURELY TIED TOGETHER WITH MEG-A-LUGS AND EITHER PRECAST OR PREFORMED CONCRETE THRUST BLOCKS.
2. ALL NUTS AND BOLTS ON HYDRANTS AND VALVES ARE TO BE STAINLESS STEEL.
3. HYDRANT AND VALVE ARE TO BE SET PLUMB AT THE ELEVATION SHOWN ON PLANS.
4. HYDRANT SHALL BE FACTORY PAINTED MATCHING THE CITY STANDARD FOR COLOR, COMMONLY KNOWN AS "PARROT GREEN", AND SHALL HAVE "HYDRAFINDER STANDARD" HYDRANT LOCATOR.

NOT TO SCALE



**CITY OF
BATAVIA**

**CITY OF BATAVIA
PUBLIC WORKS DEPARTMENT**

**SHEET: 1 OF 1
DATE: 7/10/20**

FIRE HYDRANT ASSEMBLY

STANDARD NO. 6.03