



NOTES:

1. 60" (MIN) INSIDE DIA. FOR ALL PRESSURE CONNECTION VAULTS.
2. ALL NON-PRECAST PIPE OPENINGS TO BE CORED AND RUBBER BOOTED.
3. BACKFILL MATERIAL SHALL BE IDOT CA-7 VIRGIN CRUSHED LIMESTONE.
4. CASCADE CST-EXT EXTRA HEAVY DUTY TAPPING SLEEVE WITH STAINLESS NUTS, BOLTS, AND WASHERS.
5. USE ECCENTRIC CONE ONLY.
6. VALVE VAULT MUST CONFORM TO ASTM C-478.
7. ALL SECTIONS TO BE TONGUE AND GROOVED.
8. BLOCKING SHALL NOT INTERFERE WITH BOLT MAINTENANCE OR REPLACEMENT.
9. PRIOR TO THE PLACEMENT OF FINAL LAYER OF ROADWAY, FRAMES AND ADJUSTING RINGS LOCATED WITHIN PAVED AREAS SHALL BE SET IN AN IDOT APPROVED CONCRETE "SI" MIXTURE.

NOT TO SCALE



**CITY OF
BATAVIA**

**CITY OF BATAVIA
PUBLIC WORKS DEPARTMENT**

**SHEET: 1 OF 1
DATE: 7/10/20**

WATER MAIN PRESSURE CONNECTION

STANDARD NO. 6.07