

EXISTING  
STRUCTURE

NOTES:

1. FOR PERMANENT ABANDONMENT  
REMOVE TO A POINT 1' FROM THE PUBLIC SEWER, MECHANICALLY PLUG, AND THEN SEAL WITH A FAST-SETTING MORTAR. (SEE INSET BELOW)
2. FOR RECONSTRUCTION  
IF A NEW HOME/BUILDING WILL BE CONSTRUCTED AT ANY POINT IN THE FUTURE, THE EXISTING SERVICE OR STUB WILL EITHER NEED TO BE REPLACED TO THE MAIN OR LINED (WITH WATER DEPARTMENT APPROVAL).
3. FOR RECONSTRUCTION  
CONNECT NEW P.V.C. PIPE TO A 1' LENGTH OF EXISTING PIPE USING A NON-SHEAR COUPLING.
4. IF DURING THE INSTALLATION OF THE PLUG IT IS FOUND THAT THE SERVICE CONNECTION TO MAIN IS STRUCTURALLY UNSOUND THE CONTRACTOR MUST CONTACT THE CITY OF BATAVIA
5. CITY OF BATAVIA WATER DEPARTMENT SHALL WITNESS THE ABANDONMENT PRIOR TO BACKFILLING. PLEASE CONTACT THE COMMUNITY DEVELOPMENT DEPARTMENT (630-454-2700) TO SCHEDULE THE INSPECTION.


EXISTING NON-PVC  
SERVICE TO BE REMOVED  
SEE NOTE 1

PROPERTY LINE

NOTE 2

SEE NOTE #1  
AND PLUG DETAIL

EXISTING SANITARY MAIN



**SANITARY SEWER SERVICE ABANDONMENT/RECONSTRUCTION**



**CITY OF  
BATAVIA**

**CITY OF BATAVIA  
PUBLIC WORKS DEPARTMENT**

**SHEET: 1 OF 1  
DATE: 1/26/18**

**SANITARY SERVICE ABANDONMENT**

**STANDARD NO. 5.09**